

# ARCHITECTURAL SPECIFICATION DATA

## 09 9123 - INTERIOR PAINTING

- PART 1 - GENERAL**
- 1.1. SUMMARY**
- A. THIS SECTION INCLUDES SURFACE PREPARATION AND THE APPLICATION OF PAINT SYSTEMS ON THE FOLLOWING INTERIOR SUBSTRATES AND STENCILING FIRE AND SMOKE WALLS ABOVE CEILINGS:
1. CONCRETE MASONRY UNITS (CMU)
  2. GYPSUM BOARD.
  3. GALVANIZED METAL.
  4. WOOD.
- 1.2. SUBMITTALS**
- A. PRODUCT DATA: FOR EACH TYPE OF PRODUCT INDICATED.
- B. SAMPLES FOR VERIFICATION: FOR EACH TYPE OF PAINT SYSTEM AND IN EACH COLOR AND GLOSS OF TOPCOAT INDICATED.
1. SUBMIT SAMPLES ON RIGID BACKING, 8 INCHES SQUARE.
- PART 2 - PRODUCTS**
- 2.1. PAINT, GENERAL**
- A. MATERIAL COMPATIBILITY:
1. PROVIDE MATERIALS FOR USE WITHIN EACH PAINT SYSTEM THAT ARE COMPATIBLE WITH ONE ANOTHER AND SUBSTRATES INDICATED. UNDER CONDITIONS OF SERVICE AND APPLICATION AS DEMONSTRATED BY MANUFACTURER, BASED ON TESTING AND FIELD EXPERIENCE.
- 2.2. PRIMERS/SEALERS**
- A. INTERIOR LATEX PRIMER/SEALER: WHITE, PIGMENTED, WATERBORNE LATEX SEALER USED ON NEW INTERIOR PLASTER, CONCRETE AND GYPSUM WALLBOARD SURFACES.
1. ICI PAINTS; PREP-N-PRIME INTERIOR LATEX WALL PRIMER NO. 1000-1200.
- B. WATERBORNE GALVANIZED-METAL PRIMER: WATERBORNE METAL PRIMER, COMPOSED OF ANTICORROSIIVE PIGMENTS AND ACRYLIC RESINS, FOR CLEANED/ETCHED GALVANIZED METAL.
1. ICI PAINTS; DEVOE COATINGS DEVFLEX WB DTM PRIMER FINISH NO. 90-712.
- 2.3. LATEX PAINTS**
- A. INSTITUTIONAL LOW-ODOR/VOC LATEX (FLAT): WHITE OR COLORED.
1. ICI PAINTS; CIL SELECT-INT. ACRYLIC VELVET FLAT NO. 7100.
- B. HIGH-PERFORMANCE ARCHITECTURAL LATEX (SEMIGLOSS): HIGH PERFORMANCE ARCHITECTURAL LATEX COATING, GLOSS LEVEL 5 - SEMI-GLOSS.
1. ICI PAINTS; DULUX PROFESSIONAL SEMI-GLOSS INT. WALL AND TRIM ENAMEL NO. 1406-0110.
- C. HIGH PERFORMANCE ARCHITECTURAL LATEX (LOW SHEEN)
1. ICI PAINTS; ICI DULUX INT. ACRYLIC LOW SHEEN EGGSHHELL NO. 14030.
- 2.4. WOOD PRIMERS**
- A. INTERIOR LATEX-BASED WOOD PRIMER:
1. ICI PAINTS; PREP-N-PRIME 100% ACRYLIC LATEX PRIMER NO. 2000-1200.
- 2.5. FLOOR COATINGS**
- A. INTERIOR/EXTERIOR CLEAR CONCRETE FLOOR SEALER (WATERBASED)
1. PPG; PERMA-CRETE PLEX-SEAL WB NO. 46200 (OR COMPARABLE EQUAL)
- 2.6. EPOXY PAINTS**
- A. INTERIOR/EXTERIOR EPOXY WB
1. ICI PAINTS; DEVOE COATINGS TRU GLAZE ACRYLIC EPOXY COATING NO. 4418.
- PART 3 - EXECUTION**
- 3.1. APPLICATION**
- A. APPLY PAINTS ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS.
1. USE APPLICATORS AND TECHNIQUES SUITED FOR PAINT AND SUBSTRATE INDICATED.
  2. PAINT SURFACES BEHIND MOVABLE EQUIPMENT AND FURNITURE SAME AS SIMILAR EXPOSED SURFACES. BEFORE FINAL INSTALLATION, PAINT SURFACES BEHIND PERMANENTLY FIXED EQUIPMENT OR FURNITURE WITH PRIME COAT ONLY.
  3. PAINT FRONT AND BACKSIDES OF ACCESS PANELS, REMOVABLE OR HINGED COVERS, AND SIMILAR HINGED ITEMS TO MATCH EXPOSED SURFACES.
  4. WHERE WALL BASE WILL BE INSTALLED, EXTEND PAINT NO MORE THAN 1/2 INCH BELOW TOP OF BASE.
- 3.2. INTERIOR PAINTING SCHEDULE**
- A. DRESSED LUMBER SUBSTRATES
1. HIGH-PERFORMANCE ARCHITECTURAL LATEX SYSTEM:
    - a. PRIME COAT: INTERIOR LATEX-BASED WOOD PRIMER.
    - b. INTERMEDIATE COAT: HIGH-PERFORMANCE ARCHITECTURAL LATEX MATCHING TOPCOAT.
    - c. TOPCOAT: HIGH-PERFORMANCE ARCHITECTURAL LATEX (SEMIGLOSS).
- B. GYPSUM BOARD SUBSTRATES (PAINT FINISH):
1. HIGH-PERFORMANCE ARCHITECTURAL LATEX SYSTEM:
    - a. PRIME COAT: INTERIOR LATEX PRIMER/SEALER.
    - b. INTERMEDIATE COAT: HIGH-PERFORMANCE ARCHITECTURAL LATEX MATCHING TOPCOAT.
    - c. TOPCOAT: HIGH-PERFORMANCE ARCHITECTURAL LATEX (LOW SHEEN).
- C. CONCRETE SUBSTRATES, TRAFFIC SURFACES
1. CLEAR SEALER SYSTEM:
    - a. PRIME COAT: CONCRETE FLOOR SEALER (WATERBASED)
    - b. TOPCOAT: CONCRETE FLOOR SEALER (WATERBASED)
- D. GALVANIZED METAL SUBSTRATES
1. HIGH PERFORMANCE ARCHITECTURAL LATEX SYSTEM:
    - a. PRIME COAT: WATERBORNE GALVANIZED PRIMER.
    - b. INTERMEDIATE COAT: HIGH PERFORMANCE ARCHITECTURAL LATEX MATCHING TOPCOAT.
    - c. TOPCOAT: HIGH PERFORMANCE ARCHITECTURAL LATEX SEMI-GLOSS.
- E. EXPOSED PIPES: PAINT EXPOSED PIPING FOR IDENTIFICATION IN ADDITION TO LABELS REQUIRED IN OTHER SECTIONS AS FOLLOWS:
1. HEATING HOT WATER PIPING: PINK; SHERWIN WILLIAMS NO. 6303, ROSE COLORED.
  2. DOMESTIC COLD WATER PIPING: DARK BLUE; SHERWIN WILLIAMS NO. 6244, NAVAL.
  3. DOMESTIC HOT WATER PIPING: ROSE RED; SHERWIN WILLIAMS NO. 6863, LUSTY RED.

## DIVISION 10 - SPECIALTIES

### 10 2123 - CUBICLE CURTAINS, CURTAIN AND I.V. TRACKS (CFCI)

- PART 1 - GENERAL**
- 1.1. SUMMARY**
- A. CURTAIN TRACKS AND CARRIERS
- 1.2. SUBMITTALS**
- A. PRODUCT DATA
- B. SHOP DRAWINGS
1. SHOW LAYOUT AND NUMBER OF CARRIERS, ANCHORAGE DETAILS AND CONDITIONS REQUIRING ACCESSORIES. INDICATE DIMENSIONS TAKEN FROM FIELD MEASUREMENTS.
  2. INCLUDE DETAILS ON SUPPORT AND BLOCKING ABOVE CEILING.
  3. CLEARLY INDICATE METHOD OF SECURING TRACK IS IN COMPLIANCE WITH CODE REQUIREMENTS FOR SEISMIC AREAS.
- C. SAMPLES FOR VERIFICATION - FOR EACH TYPE OF PRODUCT REQUIRED, PREPARED ON SAMPLES OF SIZE INDICATED BELOW
1. CURTAIN TRACK: NOT LESS THAN 10 INCHES (254 MM) LONG.
  2. CURTAIN CARRIER: FULL SIZE UNIT.

- PART 2 - PRODUCTS**
- 2.1. CURTAIN SUPPORT SYSTEMS**
- A. MANUFACTURERS: SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCTS BY ONE OF THE FOLLOWING:
1. C/S GENERAL CUBICLE.
  2. IMPERIAL FASTENER COMPANY, INC.
  3. INPRO CORPORATION.
- B. EXTRUDED-ALUMINUM CURTAIN TRACK: NOT LESS THAN 1-1/4 INCHES WIDE BY 3/4 INCH HIGH (32 MM WIDE BY 19 MM HIGH) MINIMUM WALL THICKNESS OF 0.062 INCH (1.57 MM).
1. CURVED TRACK: FACTORY-FABRICATED 12-INCH- (305-MM) RADIUS BENDS.
  2. FINISH: SATIN ANODIZED.
- C. CURTAIN TRACK ACCESSORIES: FABRICATE SPLICES, END CAPS, CONNECTORS, END STOPS, COUPLING AND JOINING SLEEVES, WALL FLANGES, BRACKETS, CEILING CLIPS, AND OTHER ACCESSORIES FROM SAME MATERIAL AND WITH SAME FINISH AS TRACK.
1. END STOP: NONREMOVABLE.
- D. CURTAIN CARRIERS: TWO NYLON ROLLERS AND NYLON AXLE WITH CHROME-PLATED STEEL HOOK.
- E. EXPOSED FASTENERS: STAINLESS STEEL.
- F. CONCEALED FASTENERS: STAINLESS STEEL.
- 2.2. CURTAINS**
- A. CUBICLE CURTAIN FABRIC: CURTAIN MANUFACTURER'S STANDARD, 100 PERCENT POLYESTER, INHERENTLY AND PERMANENTLY FLAME RESISTANT, STAIN RESISTANT, AND ANTIMICROBIAL.
- B. SHOWER CURTAIN FABRIC: CURTAIN MANUFACTURER'S STANDARD, 100 PERCENT POLYESTER, INHERENTLY AND PERMANENTLY FLAME RESISTANT, STAIN RESISTANT, AND ANTIMICROBIAL.
- C. CURTAIN GROMMETS: TWO-PIECE, ROLLED-EDGE, RUSTPROOF, NICKEL-PLATED BRASS; SPACED NOT MORE THAN 4 INCHES (152 MM) O.C.; MACHINED INTO TOP HEM.
- D. MESH TOP: FLAMEPROOF NYLON MESH, AT TOP OF CURTAIN WITH 1/2-INCH SPACING PER NFPA 101.
- 2.3. CURTAIN FABRICATION**
- A. FABRICATE CURTAINS TO COMPLY WITH THE FOLLOWING REQUIREMENTS:
1. WIDTH: EQUAL TO TRACK LENGTH FROM WHICH CURTAIN IS HUNG PLUS 10 PERCENT ADDED FULLNESS, BUT NOT LESS THAN 12 INCHES (305 MM) ADDED FULLNESS.
  2. LENGTH: EQUAL TO FLOOR-TO-CEILING HEIGHT, WITH 20-INCH (508-MM) MESH TOP, AND MINUS DISTANCE ABOVE THE FINISHED FLOOR AT BOTTOM AS FOLLOWS:
    - A. CUBICLE CURTAINS: 15 INCHES (381 MM).
  3. MESH TOP: TOP HEM NOT LESS THAN 1 INCH (25.4 MM) AND NOT MORE THAN 1-1/2 INCHES (38 MM) WIDE, TRIPLE THICKNESS, REINFORCED WITH INTEGRAL WEB, AND DOUBLE LOCK STITCHED. DOUBLE LOCK STITCH BOTTOM OF MESH DIRECTLY TO 1/2-INCH (13-MM) TRIPLE THICKNESS, TOP HEM OF CURTAIN FABRIC.
    - A. LABEL SHALL BE SEWN INTO TOP HEM OF EACH CURTAIN TO IDENTIFY THE WIDTH OF CURTAIN.
  4. BOTTOM HEM: NOT LESS THAN 1 INCH (25.4 MM) AND NOT MORE THAN 1-1/2 INCHES (38 MM) WIDE, DOUBLE THICKNESS AND SINGLE LOCK STITCHED.
  5. SIDE HEMS: NOT LESS THAN 1/2 INCH (13 MM) AND NOT MORE THAN 1-1/4 INCHES (32 MM) WIDE, WITH DOUBLE TURNED EDGES, AND SINGLE LOCK STITCHED.
  - B. VERTICAL SEAMS: NOT LESS THAN 1/2 INCH (13 MM) WIDE, DOUBLE TURNED AND DOUBLE STITCHED.

- PART 3 - EXECUTION**
- 3.1. INSTALLATION**
- A. INSTALL TRACKS LEVEL AND PLUMB, ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS.
- B. FIELD VERIFY DIMENSIONS PRIOR TO CURTAIN FABRICATION.
- C. CURTAINS TO BE TURNED OVER TO OWNER FOR BAR CODING PRIOR TO INSTALLATION.

### 10 2800 - TOILET AND BATH ACCESSORIES

- PART 1 - GENERAL**
- 1.1. SUMMARY**
- A. THIS SECTION INCLUDES THE FOLLOWING:
1. TOILET AND BATH ACCESSORIES.
- B. OWNER-FURNISHED/OWNER-INSTALLED MATERIAL: A1 TOILET TISSUE DISPENSER, B1 AND B2 PAPER TOWEL DISPENSER, AND J1 LIQUID-SOAP DISPENSER.
- 1.2. SUBMITTALS**
- A. PRODUCT DATA: FOR EACH TYPE OF PRODUCT INDICATED.
- B. PROJECT SCHEDULE: INDICATING TYPES, QUANTITIES, SIZES, AND INSTALLATION LOCATIONS BY ROOM OF EACH ACCESSORY REQUIRED.
1. IDENTIFY LOCATIONS USING ROOM DESIGNATIONS INDICATED ON DRAWINGS.
- PART 2 - PRODUCTS**
- 2.1. MATERIALS**
- A. STEEL SHEET: ASTM A 1008/A 1008M, DESIGNATION CS (COLD ROLLED, COMMERCIAL STEEL), 0.0359-INCH MINIMUM NOMINAL THICKNESS.
- B. GALVANIZED STEEL SHEET: ASTM A 653/A 653M, WITH G60 HOT-DIP ZINC COATING.
- C. GALVANIZED STEEL MOUNTING DEVICES: ASTM A 153/A 153M, HOT-DIP GALVANIZED AFTER FABRICATION.
- D. FASTENERS: SCREWS, BOLTS, AND OTHER DEVICES OF SAME MATERIAL AS ACCESSORY UNIT AND TAMPER-AND-THEFT RESISTANT WHERE EXPOSED, AND OF GALVANIZED STEEL WHERE CONCEALED.
- E. MIRRORS: ASTM C 1503, MIRROR GLAZING QUALITY, CLEAR-GLASS MIRRORS, NOMINAL 6.0 MM THICK.
- 2.2. TOILET AND BATH ACCESSORIES**
- A. BASIS-OF-DESIGN PRODUCT: THE DESIGN FOR ACCESSORIES IS BASED ON PRODUCTS INDICATED. SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE THE NAMED PRODUCT OR A COMPARABLE PRODUCT BY THE FOLLOWING:
1. BOBRICK WASHROOM EQUIPMENT, INC.
- B. TOILET TISSUE (CORELESS ROLL) DISPENSER:
1. OWNER FURNISHED UNIT.
- C. PAPER TOWEL (FOLDED) DISPENSER:
1. OWNER FURNISHED UNIT.
  2. MOUNTING: SURFACE MOUNTED.
  3. LARGE CAPACITY Z-FOLD TYPE.
- D. MIRROR UNIT WITHOUT SHELF:
1. BASIS-OF-DESIGN PRODUCT: BOBRICK WASHROOM EQUIPMENT, INC.; B-290.
  2. FRAME: PLASTIC LAMINATE BACKER, 2" WIDER THAN GLAZING
  3. HANGERS: PRODUCT RIGID, TAMPER- AND THEFT-RESISTANT INSTALLATION, USING METHOD INDICATED BELOW.
    - a. WALL BRACKET OF GALVANIZED STEEL, EQUIPPED WITH CONCEALED LOCKING DEVICES REQUIRING A SPECIAL TOOL TO REMOVE.
  4. GLAZING SIZES: 24" X 36"
- F. LIQUID-SOAP DISPENSER:
1. OWNER FURNISHED UNIT.
  2. MOUNTING: SURFACE MOUNTED.

### 10 2800 - TOILET AND BATH ACCESSORIES (CONTINUED)

- G. ROBE HOOK:
1. KOHLER FORTE K-11375-BN SCULPTED ROBE HOOK.
  2. DESCRIPTION: DOUBLE-PRONG UNIT.
  3. MATERIAL AND FINISH: VIBRANT BRUSHED NICKEL.
  4. MOUNTING: CONCEALED WALL PLATE.
  5. INSTALL ON THE TOILET SIDE OF EACH TOILET ROOM DOOR.
- H. GRAB BAR: REUSE EXISTING WHERE POSSIBLE.
1. BASIS-OF-DESIGN PRODUCT: BOBRICK WASHROOM EQUIPMENT, INC; B-6806X36.
    - a. MOUNTING: FLANGES WITH CONCEALED FASTENERS. HORIZONTAL MOUNT.
    - a. FOR TOILET PARTITION MOUNTING PROVIDE BOBRICK ANCHOR NO. 2583, FOR EACH FLANGE.
  3. MATERIAL: STAINLESS STEEL, 0.05 INCH THICK.
    - a. FINISH: SMOOTH, NO. 4, SATIN FINISH.
  4. OUTSIDE DIAMETER: 1-1/2 INCHES.
  5. CONFIGURATION AND LENGTH: STRAIGHT, 36 INCHES LONG.
  6. OUTSIDE DIAMETER: 1-1/2 INCHES.
- I. GRAB BAR: REUSE EXISTING WHERE POSSIBLE.
1. BASIS-OF-DESIGN PRODUCT: BOBRICK WASHROOM EQUIPMENT, INC; B-6806X48.
  2. MOUNTING: FLANGES WITH CONCEALED FASTENERS. HORIZONTAL MOUNT.
    - a. FOR TOILET PARTITION MOUNTING PROVIDE BOBRICK ANCHOR NO. 2583, FOR EACH FLANGE.
  3. MATERIAL: STAINLESS STEEL, 0.05 INCH THICK.
    - a. FINISH: SMOOTH, NO. 4, SATIN FINISH.
  4. OUTSIDE DIAMETER: 1-1/2 INCHES.
  5. CONFIGURATION AND LENGTH: STRAIGHT, 48 INCHES LONG.
  6. OUTSIDE DIAMETER: 1-1/2 INCHES.
- J. SPECIMEN PASS-THROUGH
1. BASIS-OF-DESIGN PRODUCT: BOBRICK WASHROOM EQUIPMENT, INC; B-505.
  2. FINISH: SATIN STAINLESS STEEL
- FABRICATION**
- 2.5. A. GENERAL: FABRICATE UNITS WITH TIGHT SEAMS AND JOINTS, AND EXPOSED EDGES ROLLED. HANG DOORS AND ACCESS PANELS WITH FULL-LENGTH, CONTINUOUS HINGES. EQUIP UNITS FOR CONCEALED ANCHORAGE AND WITH CORROSION-RESISTANT BACKING PLATES.
- B. FRAMED GLASS-MIRROR UNITS: FABRICATE FRAMES FOR GLASS-MIRROR UNITS TO ACCOMMODATE GLASS EDGE PROTECTION MATERIAL. PROVIDE MIRROR BACKING AND SUPPORT SYSTEM THAT PERMITS RIGID, TAMPER-RESISTANT GLASS INSTALLATION AND PREVENTS MOISTURE ACCUMULATION.
1. PROVIDE GALVANIZED STEEL BACKING SHEET, NOT LESS THAN 0.034 INCH AND FULL MIRROR SIZE, WITH NON-ABSORBEND FILLER MATERIAL. CORRUGATED CARDBOARD IS NOT AN ACCEPTABLE FILLER MATERIAL.
- C. KEYS: PROVIDE UNIVERSAL KEYS FOR INTERNAL ACCESS TO ACCESSORIES FOR SERVICING AND RESUPPLYING. PROVIDE MINIMUM OF SIZE KEYS TO OWNER'S REPRESENTATIVE.
- PART 3 - EXECUTION**
- INSTALLATION**
- 3.1. A. INSTALL ACCESSORIES ACCORDING TO MANUFACTURERS' WRITTEN INSTRUCTIONS, USING FASTENERS APPROPRIATE TO SUBSTRATE INDICATED AND RECOMMENDED BY UNIT MANUFACTURER. INSTALL UNITS LEVEL, PLUMB, AND FIRMLY ANCHORED IN LOCATIONS AND AT HEIGHTS INDICATED.
- B. CONFIRM ATTACHMENT (MECHANICAL OR ADHESIVE) AND REINFORCEMENT REQUIREMENTS OF ALL ACCESSORIES, INCLUDING OWNER-FURNISHED/CONTRACTOR-INSTALLED (OF/CI) AND OWNER FURNISHED/OWNER INSTALLED (OF/OI).
- C. GRAB BARS: INSTALL TO WITHSTAND A DOWNWARD LOAD OF AT LEAST 500 LBF, WHEN TESTED ACCORDING TO METHOD IN ASTM F 446.
- ACCESSORIES SCHEDULE AND NOTES
- 3.2. A. NOTES FOR ACCESSORIES:
1. COMPLY WITH AMERICANS WITH DISABILITIES ACT, AND OTHER APPLICABLE ACCESSIBILITY CODES FOR ACCESSIBILITY REQUIREMENTS.
  2. SEE INTERIOR ELEVATIONS IN THE DRAWINGS FOR ADDITIONAL MOUNTING HEIGHTS AND LOCATIONS FOR TOILET AND RELATED ACCESSORIES.
  3. COORDINATE WITH ARCHITECT TO FIELD LOCATE TOILET ACCESSORIES NOT LOCATED ON THE DRAWINGS.

### 10 4400 - FIRE-PROTECTION SPECIALTIES

- PART 1 - GENERAL**
- 1.1. SUMMARY**
- A. THIS SECTION INCLUDES THE FOLLOWING:
1. PORTABLE FIRE EXTINGUISHERS AND MOUNTING BRACKETS FOR WALL-HUNG FIRE EXTINGUISHERS.
- 1.2. SUBMITTALS**
- A. PRODUCT DATA: FOR EACH TYPE OF PRODUCT INDICATED. INCLUDE CONSTRUCTION DETAILS, MATERIAL DESCRIPTIONS, DIMENSIONS OF INDIVIDUAL COMPONENTS AND PROFILES, AND FINISHES FOR FIRE-PROTECTION SPECIALTIES.
1. FIRE EXTINGUISHERS: INCLUDE RATING AND CLASSIFICATION.
- B. OPERATION AND MAINTENANCE DATA: FOR FIRE EXTINGUISHERS AND CABINETS TO INCLUDE IN MAINTENANCE MANUALS.
- C. WARRANTY: SAMPLE OF SPECIAL WARRANTY.
- PART 2 - PRODUCTS**
- 2.1. ACCESSORIES**
- A. MOUNTING BRACKETS: MANUFACTURER'S STANDARD STEEL, DESIGNED TO SECURE EXTINGUISHER, OF SIZES REQUIRED FOR TYPES AND CAPACITIES OF EXTINGUISHERS INDICATED, WITH PLATED OR BLACK BAKED-ENAMEL FINISH.
1. PROVIDE BRACKETS FOR EXTINGUISHERS NOT LOCATED IN CABINETS.
- 2.2. FIRE PROTECTION EQUIPMENT**
- A. 10 LB ABC, WALL HUNG FIRE EXTINGUISHER
1. POTTER-ROEMER NUMBER 3010, 10 POUND ABC MULTI-PURPOSE DRY CHEMICAL, WALL HUNG FIRE EXTINGUISHER WITH U.L. RATING OF 4A:60B:C (OR COMPARABLE EQUAL)
- PART 3 - EXECUTION**
- 3.1. EXAMINATION**
- A. EXAMINE FIRE EXTINGUISHERS FOR PROPER CHARGING AND TAGGING.
1. REMOVE AND REPLACE DAMAGED, DEFECTIVE, OR UNDERCHARGED UNITS.
  - B. PROCEED WITH INSTALLATION ONLY AFTER UNSATISFACTORY CONDITIONS HAVE BEEN CORRECTED.
- 3.2. INSTALLATION**
- A. GENERAL: INSTALL FIRE EXTINGUISHERS IN LOCATIONS AND AT MOUNTING HEIGHTS INDICATED ON DRAWINGS. IF MOUNTING HEIGHTS ARE NOT INDICATED OBTAIN FROM ARCHITECT.
1. COMPLY WITH ADA GUIDELINES' "REACH RANGE" DIMENSIONS FOR MAXIMUM MOUNTING HEIGHTS OF CABINETS AND EXTINGUISHERS.



Design Services  
For The Built  
Environment

- Atlanta
- Birmingham
- Cincinnati
- Columbus
- Dallas
- Fort Lauderdale
- Knoxville
- Jackson
- Jacksonville
- Louisville
- Memphis
- Nashville
- Richmond
- Tampa

GRESHAM  
SMITH AND  
PARTNERS

5220 Belfort Road  
Suite 100  
Jacksonville, FL 32256  
904.332.6699  
FIRM'S FLORIDA  
CERT. NO.  
AAP000034/EB0003806  
1826000797



## Renovation and Finish Upgrade

DRS. GIBSON & RAYMAKER  
400 Healthpark Boulevard  
St. Augustine, FL 32086

### CONSTRUCTION DOCUMENTS

SEAL:

HILLARY MCDONALD  
ID 5463

### REVISION

No.	Date	Revision

SPECIFICATIONS

# A4.5

Drawn By:  
Checked By:  
Approved By:

\$LEV1\$  
\$LEV2\$  
\$LEV3\$  
\$LEV4\$  
\$LEV5\$  
\$LEV6\$  
\$LEV7\$

\$LEV1\$  
\$LEV2\$  
\$LEV3\$  
\$LEV4\$  
\$LEV5\$  
\$LEV6\$  
\$LEV7\$

\$DCAF\$  
\$REF1\$  
\$REF2\$  
\$REF3\$  
\$REF4\$  
\$REF5\$  
\$REF6\$  
\$REF7\$

\$INSTR\$  
\$DANTE\$  
\$TTIME\$  
\$REF1\$  
\$REF2\$  
\$REF3\$  
\$REF4\$  
\$REF5\$

\$USER\$